ICC-ES Listing Report

ESL-1247

Reissued July 2026

Subject to renewal July 2027

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.

Copyright © 2026 ICC Evaluation Service, LLC. All rights reserved.

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION **Section: 07 46 43—Composition Siding**	**LISTEE:** **EVOLVE STONE, INC.**	**PRODUCT:** **EVOLVE STONE – FIRE RATED**	

PRODUCT CERTIFICATION SYSTEM:

The ICC-ES product-certification system includes evaluated evidence in support of test data in accordance with the standard(s) listed below. The product and system also involves factory inspections, and assessment and surveillance of the listee's quality system.

EVALUATION:

Evolve Stone – Fire Rated units are made of polymer-based material that is cast into a variety of sizes that are intended to appear as dry stacked natural stone when installed. The products have a nominal density of 33.8 lb./ft^3 (541 kg/m^3) and are cast with an irregular face to simulate a natural stone finish. Evolve Stone – Fire Rated units were evaluated when tested to an average thickness of 0.636 inch (16 mm) to the following standard:

- ASTM E84-16 and ASTM E84-2013a, Standard Test Method for Surface Burning Characteristics of Building Materials, ASTM International.

FINDINGS:

Evolve Stone – Fire Rated units have a flame-spread index and smoke-developed index as specified in Table 1 (Class B for interior use only) below based on testing in accordance with ASTM E84.

TABLE 1—FLAME-SPREAD INDEX AND SMOKE-DEVELOPED INDEX

PRODUCT	FLAME-SPREAD INDEX (FSI)	SMOKE-DEVELOPED INDEX (SDI)
EVOLVE STONE – FIRE RATED	75	450

IDENTIFICATION:

1. The Evolve Stone – Fire Rated units are labeled with the manufacturer's name (Evolve Stone, Inc.); manufacturing date, lot number, and the ICC-ES listing report number (ESL-1247), and the ICC-ES listing mark.

2. The report holder's contact information is the following:
   EVOLVE STONE, INC.
   200 LENOIR DRIVE, UNIT B
   WINCHESTER, VIRGINIA 22603
   (703) 646-8090
   www.evolvestone.com

INSTALLATION

The product must be installed in accordance with the Evolve Stone, Inc's published installation instructions and as required by the Authority Having Jurisdiction (AHJ).

CONDITIONS OF LISTING:

1. The listing report addresses only conformance with the standard noted above.
2. The report user shall provide evidence of code compliance using this report, in accordance with the design application, for the Authority Having Jurisdiction (AHJ) review and approval.
3. The listing report applies only to the materials tested and as submitted for review by ICC-ES.
4. The Evolve Stone – Fire Rated units are manufactured in Winchester, Virginia, under a quality control program with inspections by ICC-ES.